

AE-FSPM-0305
05 Sep 23


FUEL QUALITY TEST RECORD

AGENCY: _____

DATE: _____

AIRPORT: _____

FACILITY: _____

SAMPLING PORT	FILTRATION MEMBRANE TEST (MILLIPORE) ASTM D2276	WATER TEST
<p>AFTER FILTRATION</p> <p>() PARTICULATE () CLAY () FILTER/ SEPARATOR () FILTER MONITOR () DIRT DEFENSE () WATER BARRIER</p> <p>DIFFERENTIAL PRESSURE: _____ psi</p> <p>UNIT NO. _____</p>	 <p>ATTACH MEMBRANE</p>	<p>(30 ppm allowable)</p> <p>PPM = _____</p>

DRY RATING: _____
SAMPLE SIZE (GAL): _____
NOTE: ONE GALLON FLUSH - ONE GALLON SAMPLE

SIGNATURE OF PERSON PERFORMING TASK

REMARKS:

RETAIN ON FILE FOR 12 MONTHS