

AIRCRAFT FUELING EQUIPMENT CHECKS				STATION:	EQUIPMENT ID:	YEAR:
QUARTERLY		1ST QTR	2ND QTR	3RD QTR	4TH QTR	
1. VEHICLE INSPECTION	CONDITION CODE CHECKED BY & DATE:					
2. PRESSURE CONTROLS	CONDITION CODE PRIMARY FUEL PRESSURE SETTING (PSI) SECONDARY FUEL PRESSURE SETTING (PSI)					
3. WATER DEFENSE SYSTEM - EXTERNAL CHECK	CHECKED BY & DATE: CONDITION CODE CHECKED BY & DATE:					
4. INTERNAL VALVE CHECK	CONDITION CODE CHECKED BY & DATE: CONDITION CODE CHECKED BY & DATE:					
5. INTERLOCK OVERRIDE FUNCTION CHECK	CONDITION CODE CHECKED BY & DATE: CONDITION CODE CHECKED BY & DATE:					
6. SURGE ABSORBERS	CONDITION CODE CHECKED BY & DATE:					
7. DIFFERENTIAL PRESSURE LIMITING DEVICE	CONDITION CODE CHECKED BY & DATE:					

**SEMI-ANNUAL (ONLY REQUIRED IF USING REUSEABLE COUPLINGS ON FUEL HOSES)**

ID #	ID #	ID #	ID #
1. PERIODIC HOSE PRESSURE TEST			
TEST PRESSURE (PSI)			

**ANNUAL**

1a. FILTER WATER SEPARATOR ANNUAL INSPECTION/CLEANING <i>Use form 103.09A (req. every 12 months)</i>	Use form 103.09A	3. DIFFERENTIAL PRESSURE GAUGE	CONDITION CODE CHECKED BY & DATE:
1b. FILTER MONITOR ANNUAL ELEMENT CHANGE <i>Use form 103.09B (req. every 12 months or when DP is 15psi)</i>	Use form 103.09B	4. METER CALIBRATION	CONDITION CODE CHECKED BY & DATE:
1c. WATER BARRIER ANNUAL ELEMENT CHANGE <i>Use form 103.09B (req. every 12 months or when DP is 22psi)</i>	Use form 103.09B	5. WATER DEFENSE SYSTEM INSPECTION & TEST	CONDITION CODE CHECKED BY & DATE:
1d. FILTER WATER SEPARATOR/DIRT DEFENSE ELEMENT CHANGE <i>Use form 103.09B (req. every 36 months or when DP is 15psi)</i>	Use form 103.09B	6. HYDRANT PIT COUPLERS	CONDITION CODE CHECKED BY & DATE:
1e. DIRT DEFENSE FILTER ANNUAL INSPECTION/CLEANING <i>Use form 103.09C (req. every 12 months)</i>	Use form 103.09C	7. FILTER VESSEL PRESSURE RELIEF DEVICES	CONDITION CODE CHECKED BY & DATE:
2. FUELING PRESSURE GAUGES		8. EI 1598 TYPE ELECTRONIC WATER SENSOR	CONDITION CODE CHECKED BY & DATE:

**REMARKS:**


CONDITION CODES: S = SATISFACTORY; C = COMMENT (COMMENT REQUIRED IN REMARKS SECTION); N/U = NOT USED; N/A = NOT APPLICABLE  
RETAIN ON FILE FOR 12 MONTHS