

AE-FSPM-0307
03 Nov 09

Daily Fueling Equipment Checklist

Daily - Use applicable Rating	Station - (a)								Equip. ID# - (b)								Month (c)		Year (c)														
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
1. General Condition	(d)																																
2. Filter Sumps - Record Ratings																																	
3. Filter Differential Pressure - psi																																	
4. Deadman Control																																	
5. Brake Safety Interlocks																																	
6. Nozzle Fueling Pressure																																	
7. Hose, Nozzles and Swivels																																	
8. Static Reels, Cables and Clamps																																	
9. Lift Platforms																																	
10. Fire Extinguishers																																	
11. Surge/Waste Tanks																																	
12. Air Tanks																																	
13. Tanker Troughs																																	
14. Tank Sumps - Record Ratings																																	
15. Tanker Bottom loading Per-Check																																	
Signature of person performing task or person accepting responsibility that tasks were performed.	(e)																																
Ratings: S = Satisfactory C = Comment (Comment required in Remarks Section): N/U = Not Used N/A = Not Applicable																																	
Sump Sample Ratings: Solids - 1 = Clean 2 = Slight 3 = Particulate 4 = Dirty: Water - A = Bright B = Hazy C = Cloudy D = Wet																																	
Remarks: (f)																																	
Retain on file for 24 months																																	